

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/13/2012  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>15G221</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>06/12/2012</b>	
NAME OF PROVIDER OR SUPPLIER  <b>ADEC INC</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>59796 PARK SIDE</b> <b>ELKHART, IN 46517</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification Survey conducted on 05/16/12 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j).</p> <p>Survey Date: 06/12/12</p> <p>Facility Number: 000745 Provider Number: 15G221 AIM Number: 100234850</p> <p>Surveyor: W. Chris Greeney, Life Safety Code Specialist</p> <p>At this PSR survey, ADEC, Inc. was found in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 32, New Residential Board and Care Occupancies.</p> <p>This one story facility with a finished basement was fully sprinklered. The facility has a monitored fire alarm system with smoke detection on both levels including in the corridors, client sleeping rooms and common living areas. The facility has a capacity of 8 and had a census of 8 at the time of this survey.</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A, Alternative Approaches to Life Safety, Chapter 6, rated the facility Prompt with an E-Score of 0.32.</p> <p>Quality Review by Robert Booher, Life Safety</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/13/2012  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>15G221</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>06/12/2012</b>	
NAME OF PROVIDER OR SUPPLIER  <b>ADEC INC</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>59796 PARK SIDE</b> <b>ELKHART, IN 46517</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	Continued From page 1 Code Specialist-Medical Surveyor on 06/12/12.			{K 000}			